

Software		WinCC Version		SIMATIC WinCC V6.2					
				V6.2		V6.2 SP2		V6.2 SP3	
				Client ¹⁾ / Singlestation	Server	Client / Singlestation	Server	Client / Singlestation	Server
Microsoft Windows ^{*4, 15)}	2000 Professional SP4 (KB828741)		x		x		x		
	XP Professional SP2 (KB319740)		x		x		x		
	XP Professional SP3						x		
	Server 2003 SP1 ^{**11)}		x ^{*14)}	x					
	Server 2003 SP2 (KB929046) ^{**11)}				x ^{*8, 14)}	x	x ^{*8, 14)}	x	
	Server 2003 R2 ^{**11)}		x ^{*14)}	x					
	Server 2003 R2 SP2 (KB929046) ^{**11)}				x ^{*8, 14)}	x	x ^{*8, 14)}	x	
Microsoft Internet Explorer	V6.0 SP1		x		x		x		
	V6.0 SP2		x		x		x		
	V7.0				x		x		
Virus Scanner	Trend Micro Server Protect V5.56		x						
	Trend Micro Server Protect V5.58		x						
	Trend Micro OfficeScan NT ab 5.02		x						
	Trend Micro OfficeScan V7.3 ^{**12)}		x						
	Trend Micro OfficeScan V7.3 incl. Patch 2 ^{**12)}				x		x		
	Trend Micro OfficeScan V10.5 incl. Patch 1 (Build 1799) ^{**12)}						x		
	McAfee VirusScan Enterprise V8.0i incl. Patch 11 (KB43256)		x						
	McAfee VirusScan Enterprise V8.5				x		x		
	Symantec AntiVirus Corporate Edition V8.1		x						
	Symantec AntiVirus Corporate Edition V10.0 (Norton Antivirus)		x						
	Symantec AntiVirus Corporate Edition V10.2 (Norton Antivirus)				x		x		
Remote Software	Symantec pcAnywhere V11.5		x ^{*13)}		x ^{*13)}		x ^{*13)}		
	Microsoft Windows NetMeeting		x ^{*2)}		x ^{*2)}		x ^{*2)}		
OPC	OPC Data Access Spezifikation	V2.05a ^{*19)}	x ^{*16)}	x	x ^{*16,17)}	x ^{*17)}	x ^{*16,17)}	x ^{*17)}	
		V3.00 ^{*19)}	x ^{*16)}	x	x ^{*16,17)}	x ^{*17)}	x ^{*16,17)}	x ^{*17)}	
	OPCS Historical Data Access (HDA) ^{*18)}	V1.20 ^{*19)}	x ^{*16)}	x	x ^{*16)}	x	x ^{*16)}	x	
	OPC Alarms and Events (A&E) ^{*18)}	V1.10 ^{*19)}	x ^{*16)}	x	x ^{*16)}	x	x ^{*16)}	x	
	OPC XML Data Access ^{*18)}	V1.00	x ^{*16)}	x	x ^{*16)}	x	x ^{*16)}	x	
Automation License Manager	V3.0		x						
	V3.0 SP1				x		x		
WinCC Smart Tools	WinCC Configuration Tool				x ^{*3)}				
	WinCC Archive Configuration Tool				x ^{*3)}				
	WinCC CrossReferenceAssistant				x				
	WinCC Communication Configurator				x				
	Variablen Export/Import				x				
	Variablensimulator				x				
	Dynamic Wizard Editor				x				
	Documentation Viewer				x				
Easy Language				x					
STEP 7 ^{**10)}	V5.4 SP1		x		x		x		
	V5.4 SP2		x		x		x		
	V5.4 SP3		x		x		x		
	V5.4 SP4				x				
	V5.4 SP5				x (ab WinCC HF8)		x		
SIMATIC NET ^{*9)}	Edition 2006 (V6.4)		x ^{*5, 6)}		x ^{*5, 6)}		x ^{*5, 6)}		
WinCC/Audit	V6.2		x		x		x		
WinCC/Central Archive Server (CAS)	V6.2		x						
	V6.2 SP2				x				
	V6.2 SP3						x		
WinCC/Connectivity Pack/Station	V6.2		x						
	V6.2 SP2				x				
	V6.2 SP3						x		

Software	WinCC Version	SIMATIC WinCC V6.2		
		V6.2	V6.2 SP2	V6.2 SP3
WinCC/DataMonitor	V6.2	x		
	V6.2 SP2		x	
	V6.2 SP3			x
WinCC/Downtime Monitor	V1.0	x		
	V1.0 SP1		x	x
WinCC/Industrial DataBridge	V6.1	x	x	x
WinCC/IndustrialX	V6.2	x	x	x
WinCC/ODK	V6.0 SP4	x	x	x
WinCC/ProAgent ^{*7)}	V6.0 SP4	x	x	x
WinCC/Process Monitor	V 1.0	x		
	V1.0 SP1		x	x
WinCC/Redundancy	V6.2	x	x	x
WinCC/Server	V6.2	x	x	x
WinCC/User Archives	V6.2	x	x	x
WinCC/Web Navigator	V6.2	x		
	V6.2 SP2		x	
	V6.2 SP3			x
BATCH (für WinCC)	V7.0	x		
	V7.0 SP1		x	
WinCC powerrate	V3.0 SP1		x	x
Simatic Logon	V1.3 SP1	x		
	V1.4	x		
	V1.4 SP1	x	x	x
	V1.4 SP2	x	x	x
Maintenance Station	V1.4 SP3	x	x	x
	2007	x		
	2007 SP1	x		
	2007 SP2		x	
	2007 SP3		x	
WinBDE	2007 SP4		x	x
	V7.2 SP2	x	x	x

*1) All WinCC Clients of a project must be installed with the same version of the operating system (inclusive SP).

*2) More information on installing and configuring "Microsoft Windows NetMeeting" is available on the Microsoft sites at <http://support.microsoft.com/kb/154144/> and <http://support.microsoft.com/kb/158623/>

*3) It is not absolutely necessary to have WinCC installed. In this case you cannot read/write data from/to WinCC. But it is a requirement to install MS Excel 2000 / XP /2003.

*4) WinCC is only released for 32-Bit operating systems.

*5) WinCC is delivered with SIMATIC NET Softnet-S7 Lean

*6) In combination with WinCC is SIMATIC NET Edition 2006 released for Windows Server 2003 R2 SP2, Windows Server 2003 SP2 and Windows XP SP3.

*7) WinCC/ProAgent V6.0 SP4 is only released as single-user system for WinCC

*8) The MUI version of Windows Server 2003 SP2 and Windows Server 2003 R2 SP2 additionally require the Microsoft MUI patch KB925148.

*9) Notice operating system, entry 9859007

*10) Notice operating system, entry 8250891

*11) Standard und Enterprise Edition

*12) Only the "Corporate Edition" of Trend Micro OfficeScan virusscanner is released.

*13) As from WinCC V6.2 the software "Microsoft Windows NetMeeting" is released for Remote Service access and Remote Operation. The pcAnywhere Host V11.5 software will still be supported during the transition phase.

*14) Clients without own project are not allowed for operating system Windows Server 2003 (R2).

*15) Don't use an older Windows Server version on the WinCC Client as at the WinCC Server.

*16) Installation of WinCC OPC Server is only released on WinCC client with own project.

*17) OPC DA is possible in WinCC Demo mode with WinCC V6.2 SP2 HF4 or higher.

*18) OPC HDA, OPC A&E and OPC XML DA is not possible in WinCC Demo mode. You need a WinCC ConnectivityPack license.

*19) OPC DA, OPC A&E and OPC HDA is released for Connectivity Station. ConnectivityStation is not possible in WinCC Demo mode.